



Dr. Ing. Leonardo Bonini INGEGNERIA della SICUREZZA, AMBIENTE e della QUALITA'



通讯 N. 4 / 2020

压力下的电器 - 不要忘记它们

报道不幸的是，最近发生的事故越来越多，即使不是新闻的焦点，我们借此机会提醒您，压力设备每天都在同一地点；几乎所有的东西都被我们盯着，其他隐藏在例如用于空气制冷的压缩机的容器中。他们的日常工作使我们忘记了，在调试之后，他们也需要维护以突出阻塞，腐蚀以及不再使用经过校准的安全装置。

附件七中的第 81/2008 号法令明确说明了检查的时间

Equipment (name used in Allegato VII D.Lgs. 81/2008)	Intervention/periodicity
Equipment/sets containing group fluids 1 (D.lgs. 93/2000 art. 3) Containers/set classified in category III and IV, vessels containing unstable gases belonging to category I to IV, furnaces for chemical and related industries, generators and containers for non-water overheated liquids.	Operation check: two-year Integrity check: 10-year
Equipment/sets containing group fluids 1 (D.lgs. 93/2000 art. 3) Recipients/set classified in category I and II.	Operation check: four-year Integrity check: 10-year
Equipment/sets containing group 1 fluids (D.lgs. 93/2000 art. 3) Gas pipes, vapours and overheated liquids classified in category I, II and III	Operation check: five-year Integrity check: 10-year
Equipment/set containing group 1 fluids (D.lgs. 93/2000 art. 3) Liquid pipes classified in category I, II and III	Operation check: five-year Integrity check: 10-year
Equipment/sets containing group 1 fluids (D.lgs. 93/2000 art. 3) Containers for liquids belonging to category I, II and III.	Operation check: five-year Integrity check: 10-year
Equipment/sets containing group fluids 2 (D.lgs. 93/2000 art. 3) Containers/sets containing compressed gases, liquefied and dissolved or vapors other than the water vapor classified in category III and IV, and vessels of water vapour and overheated water belonging to categories I to IV	Operation check: three-year Integrity check: 10-year
Equipment/sets containing group fluids 2 (D.lgs. 93/2000 art. 3) Containers/sets containing compressed/gases, liquefied and dissolved or vapours other than water vapor classified in I and II category	Operation check: four-year Integrity check: 10-year



Intertek STUDIO CERTIFICATO UNI EN ISO 9001:2015 Mixed Quality. Delivered. Certificato No. 1215872-01

Via Galliera n°34, 40121 BOLOGNA Tel.: +39 051 240 241-FAX: +39 051 716 032 3

E-mail: l.bonini@leonardobonini.com Web: www.leonardobonini.com



Dr. Ing. Leonardo Bonini INGENNERIA della SICUREZZA, AMBIENTE e della QUALITA'

Equipment/sets containing group 2 fluids (D.lgs. 93/2000 art. 3) Watervapor generators . /	Operation check: two-year Internal visit: biennial Integrity check : ten years
Equipment/sets containing group fluids 2 (D.lgs. 93/2000 art. 3) Gas pipes, vapours and overheated liquids classified in category III, having TS < 350 degrees Celsius	Integrity check 10-year
Equipment/setscontaining group fluids 2 (D.lgs. 93/2000 art. 3) Gas pipes, vapours and overheated liquids classified in category III, having TS > 350 degrees Celsius	Verification of operation: five-year Integrity check:10-year
Hea generators powered by solid, liquid or gas fuel for central heating systems using hot water under pressure with water temperature not exceeding the temperature boiling at atmospheric pressure, having global potential of outbreaks above 116 kW	Five-year verification

请记住，每次检查时都必须更换安全阀，方法是拆卸已安装的安全阀并重新组装新的或现有的已重新校准的安全阀。

工作室 Ing. Leonardo Bonini 莱昂纳多博士可澄清

博洛尼亚 14/04/2020



Intertek STUDIO CERTIFICATO UNI EN ISO 9001:2015 Value Quality. Delivered. Certificato No. 1215872-01

Via Galliera n°34, 40121 BOLOGNA Tel.: +39 051 240 241–FAX: +39 051 716 032 3

E-mail: l.bonini@leonardobonini.com Web: www.leonardobonini.com